GF-P110-3-0001 Generator





Output Prime kVA	100
Output Prime kW	80
Enclosure Type	Open Set
Fuel Capacity (L)	303
Fuel Cons L/hr 100% Prime	21.7
Run HRs 100% Prime	14.0
Fuel Cons. @ 75% Load (L/Hr)	16.5
Fuel Cons. 50% Load (L/Hr)	11.6
Bunded	No


Generator Configuration

415
Comap MRS-16
STD
4 Pole
Yes
No
No
No

Alternator Data

Alternator Brand	LeRoy Somer
Alternator Model	LL3114F
Prime Amps per φ	139
AVR Model	R250
Volt Reg	+/- 0.5%
Insulation Class	Н
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

LENGTH	1980mm	WIDTH	890mm
HEIGHT	1374mm	DOOR	0mm
WEIGHT	1330kg		



Engine Data

Engine Brand	Perkins	
Engine Model	1104C-44TAG2	
Number of Cylinders	4 - In Line	
Governor	Electronic	
Induction	Turbo Air to Air Charged	
Compression ratio	18.3:1	
Displacement	4.40	
Alternator Charge Amp	65	
Filter Type (Fuel)	Replaceable Element	
Fuel Class	A2 Diesel	
Air Filter Type	Replaceable Element	
Oil Filter Type	Spin-On, Full Flow	
Total Oil Capacity	8.00	
Oil Type	API CC/SE	

Prime Rating

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	CTI160
Noise (dBA) @ 1m 100% Load	N/A
Noise (dBA) @ 1m 75% Load	N/A
Noise (dBA) @ 7m 100% Load	N/A
Noise (dBA) @ 7m 75% Load	N/A





