# GF-PRO-275-0999 Generator






### **Generator Configuration**

Voltage	415
Control Panel	DSE7310
Base Tank Type	Bunded
Circuit Breaker	4 Pole
Mains Charger	Yes
Lifting Frame	Yes
Forklift Pocket Skid	Yes
Water Jacket Heater	No

### Alternator Data

Alternator Brand	LeRoy Somer
Alternator Model	LL5114J
Prime Amps per $\phi$	383
AVR Model	R250
Volt Reg	+/- 0.5%
Insulation Class	Н
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

LENGTH	4065mm	WIDTH	1400mm
HEIGHT	2124mm	DOOR	1000mm
WEIGHT	4390kg		<u></u>



Output Prime kVA	275
Output Prime kW	220
Enclosure Type	Rental
Fuel Capacity (L)	592
Fuel Cons L/hr 100% Prime	62.5
Run HRs 100% Prime	9.5
Fuel Cons. @ 75% Load (L/Hr)	47.3
Fuel Cons. 50% Load (L/Hr)	33.8
Bunded	Yes

# Engine Data

Engine Brand	Perkins
Engine Model	1506D-E88TAG4
Number of Cylinders	6 - In Line
Governor	Electronic
Induction	Turbocharged
Compression ratio	16.1:1
Displacement	8.80
Alternator Charge Amp	45
Filter Type (Fuel)	Replaceable Element
Fuel Class	A2 Diesel
Air Filter Type	Replaceable Element
Oil Filter Type	Spin On Full Flow
Total Oil Capacity	39.00
Oil Type	API CH4 15W-40


## **Prime Rating**

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

## Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	ATI630
Noise (dBA) @ 1m 100% Load	80
Noise (dBA) @ 1m 75% Load	77
Noise (dBA) @ 7m 100% Load	69
Noise (dBA) @ 7m 75% Load	66







**ALLIGHTSYKES**