# GF-PRO-60-0999 Generator





Output Prime kVA	60
Output Prime kW	48
Enclosure Type	Rental
Fuel Capacity (L)	301
Fuel Cons L/hr 100% Prime	16.5
Run HRs 100% Prime	18.2
Fuel Cons. @ 75% Load (L/Hr)	12.4
Fuel Cons. 50% Load (L/Hr)	8.3
Bunded	Yes


## **Generator Configuration**

Voltage	415
Control Panel	DSE7310
Base Tank Type	Bunded
Circuit Breaker	4 Pole
Mains Charger	Yes
Lifting Frame	Yes
Forklift Pocket Skid	Yes
Water Jacket Heater	No

### **Alternator Data**

Alternator Brand	LeRoy Somer
Alternator Model	LL1514P
Prime Amps per φ	83
AVR Model	R250
Volt Reg	+/- 0.5%
Insulation Class	Н
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

LENGTH	2610mm	WIDTH	1120mm
HEIGHT	1777mm	DOOR	860mm
WEIGHT	1980kg		



# **Engine Data**

Engine Brand	Perkins
Engine Model	1104D-44TG2
Number of Cylinders	4 - In Line
Governor	Electronic
Induction	Turbocharged
Compression ratio	18.23:1
Displacement	4.40
Alternator Charge Amp	65
Filter Type (Fuel)	Replaceable Element
Fuel Class	A2 Diesel
Air Filter Type	Replaceable Element
Oil Filter Type	Spin On Full Flow
Total Oil Capacity	7.00
Oil Type	API CG4/CH4 15W-40

## **Prime Rating**

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

#### Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	CTI125
Noise (dBA) @ 1m 100% Load	74
Noise (dBA) @ 1m 75% Load	73
Noise (dBA) @ 7m 100% Load	65
Noise (dBA) @ 7m 75% Load	63







