

GF-P110-3-0001 Generator



Output Prime kVA	100
Output Prime kW	80
Enclosure Type	Open Set
Fuel Capacity (L)	303
Fuel Cons L/hr 100% Prime	21.7
Run HRs 100% Prime	14.0
Fuel Cons. @ 75% Load (L/Hr)	16.5
Fuel Cons. 50% Load (L/Hr)	11.6
Bunded	No

Generator Configuration

Voltage	415
Control Panel	Comap MRS-16
Base Tank Type	STD
Circuit Breaker	4 Pole
Mains Charger	Yes
Lifting Frame	No
Forklift Pocket Skid	No
Water Jacket Heater	No

Engine Data

Engine Brand	Perkins
Engine Model	1104C-44TAG2
Number of Cylinders	4 - In Line
Governor	Electronic
Induction	Turbo Air to Air Charged
Compression ratio	18.3:1
Displacement	4.40
Alternator Charge Amp	65
Filter Type (Fuel)	Replaceable Element
Fuel Class	A2 Diesel
Air Filter Type	Replaceable Element
Oil Filter Type	Spin-On, Full Flow
Total Oil Capacity	8.00
Oil Type	API CC/SE

Alternator Data

Alternator Brand	LeRoy Somer
Alternator Model	LL3114F
Prime Amps per ϕ	139
AVR Model	R250
Volt Reg	+/- 0.5%
Insulation Class	H
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

Prime Rating


These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	CT1160
Noise (dBA) @ 1m 100% Load	N/A
Noise (dBA) @ 1m 75% Load	N/A
Noise (dBA) @ 7m 100% Load	N/A
Noise (dBA) @ 7m 75% Load	N/A

LENGTH	1980mm	WIDTH	890mm
HEIGHT	1374mm	DOOR	0mm
WEIGHT	1330kg		



Scan QR code
for product info

