# GF-P330-5-0996 Generator





Output Prime kVA	300
Output Prime kW	240
Enclosure Type	Level 1 High Ambient
Fuel Capacity (L)	503
Fuel Cons L/hr 100% Prime	62.8
Run HRs 100% Prime	8.0
Fuel Cons. @ 75% Load (L/Hr)	46.6
Fuel Cons. 50% Load (L/Hr)	43.3
Bunded	D/Skin Tank

## **Generator Configuration**

Voltage	415
Control Panel	Comap MRS-16
Base Tank Type	Dual Wall
Circuit Breaker	4 Pole
Mains Charger	Yes
Lifting Frame	Yes
Forklift Pocket Skid	No
Water Jacket Heater	No

### **Alternator Data**

Alternator Brand	LeRoy Somer
Alternator Model	LL5114J
Prime Amps per φ	417
AVR Model	R250
Volt Reg	+/- 0.5%
Insulation Class	Н
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

LENGTH	3975mm	WIDTH	1400mm
HEIGHT	2132mm	DOOR	994mm
WEIGHT	3430kg		



# **Engine Data**

Perkins	
1506A-E88TAG5	
6 - In Line	
Electronic	
Turbo Air to Air Charged	
16.1:1	
8.80	
45	
Replaceable Element	
A2 Diesel	
Replaceable Element	
Spin-On, Full Flow	
39.00	
API CI-4 0W-30	

## **Prime Rating**

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

#### Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	ATI630
Noise (dBA) @ 1m 100% Load	77
Noise (dBA) @ 1m 75% Load	76
Noise (dBA) @ 7m 100% Load	69
Noise (dBA) @ 7m 75% Load	68



