GF-P40-3S-0999 Generator





Output Prime kVA	36
Output Prime kW	36
Enclosure Type	CAL/G Metal Canopy
Fuel Capacity (L)	194
Fuel Cons L/hr 100% Prime	10.2
Run HRs 100% Prime	19.0
Fuel Cons. @ 75% Load (L/Hr)	7.7
Fuel Cons. 50% Load (L/Hr)	5.7
Bunded	Yes


Generator Configuration

Voltage	240
Control Panel	Comap MRS-16
Base Tank Type	Bunded-FB6
Circuit Breaker	3 Pole
Mains Charger	Yes
Lifting Frame	Yes
Forklift Pocket Skid	Yes
Water Jacket Heater	No

Alternator Data

Alternator Brand	LeRoy Somer
Alternator Model	LLB1514P
Prime Amps per φ	150
AVR Model	R220
Volt Reg	+/- 1.0%
Insulation Class	Н
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

LENGTH	2291mm	WIDTH	1026mm
HEIGHT	1733mm	DOOR	994mm
WEIGHT	1430kg		



Engine Data

Engine Brand	Perkins
Engine Model	1103A-33TG1
Number of Cylinders	3 - In Line
Governor	Mechanical
Induction	Turbocharged
Compression ratio	17.25:1
Displacement	3.30
Alternator Charge Amp	65
Filter Type (Fuel)	Replaceable Element
Fuel Class	A2 Diesel
Air Filter Type	Replaceable Element
Oil Filter Type	Spin-On, Full Flow
Total Oil Capacity	8.30
Oil Type	API CG4/CH4 15W-40

Prime Rating

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	ATI250
Noise (dBA) @ 1m 100% Load	74
Noise (dBA) @ 1m 75% Load	73
Noise (dBA) @ 7m 100% Load	64
Noise (dBA) @ 7m 75% Load	62

