# GF-P55-3-0999 Generator





Output Prime kVA	50
Output Prime kW	40
Enclosure Type	CAL/G Metal Canopy
Fuel Capacity (L)	145
Fuel Cons L/hr 100% Prime	11.6
Run HRs 100% Prime	12.5
Fuel Cons. @ 75% Load (L/Hr)	8.7
Fuel Cons. 50% Load (L/Hr)	6.2
Bunded	Yes


## **Generator Configuration**

Voltage	415
Control Panel	Comap MRS-16
Base Tank Type	Bunded-FB6
Circuit Breaker	4 Pole
Mains Charger	Yes
Lifting Frame	Yes
Forklift Pocket Skid	Yes
Water Jacket Heater	No

### **Alternator Data**

Alternator Brand	LeRoy Somer
Alternator Model	LL1514N
Prime Amps per φ	69
AVR Model	R220
Volt Reg	+/- 0.5%
Insulation Class	Н
Winding Pitch	2/3
Excitation	Shunt
Frequency (Hz)	50

LENGTH	2291mm	WIDTH	1026mm
HEIGHT	1707mm	DOOR	1000mm
WEIGHT	1210kg		



# **Engine Data**

Engine Brand	Perkins
Engine Model	1103A-33TG2
Number of Cylinders	3 - In Line
Governor	Mechanical
Induction	Turbocharged
Compression ratio	17.25:1
Displacement	3.30
Alternator Charge Amp	65
Filter Type (Fuel)	Replaceable Element
Fuel Class	A2 Diesel
Air Filter Type	Replaceable Element
Oil Filter Type	Spin-On, Full Flow
Total Oil Capacity	8.30
Oil Type	API CG4/CH4 15W-40

## **Prime Rating**

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

#### Standard Reference Conditions

Note: Standard reference conditions 25°C Air Inlet Temp, 100m MASL, 30% Relative Humidity, dB(A) are free field.

Mains Failure Transfer Panel (Option)	CTI125
Noise (dBA) @ 1m 100% Load	74
Noise (dBA) @ 1m 75% Load	73
Noise (dBA) @ 7m 100% Load	64
Noise (dBA) @ 7m 75% Load	62



